



984 Gorham Street, Newmarket, ON L3Y 1L8

Administration: 905-895-9222

Emergency: 9-1-1

Central York Fire Services Incident Report

Incident Type: Small Fire

Date: Tuesday, April 13, 2016

Time of Call: 9:45 a.m.

Ward: 5

Address / location of incident: 221 Main Street South, Newmarket

Description: Central York Fire Services (CYFS) was on the scene of a small fire on Main Street South in Newmarket. The small fire was within a second floor residential occupancy under renovation.

Cause of incident: Fire was caused by a floor sander causing sparks from nails igniting sawdust within the sanding machine and igniting an adjacent wall.

Casualties / Injuries: There are no reported casualties or injuries

Community Impact: Main Street South was closed to all traffic between Water Street and Park Avenue for approximately 35 minutes while fire crews dealt with the fire.

Current Status: Fire is extinguished and the property was turned over to the building owner.

Resources Used: CYFS had four CYFS vehicles on scene and 13 personnel in addition to Fire Prevention personnel.

For more information contact:

Wanda Bennett | Director of Communications | Town of Newmarket

Phone: 905-953-5300 ext. 2041 | Email: wbennett@newmarket.ca